

**PERFORMANCE TEST OF  
POCKET FILTER FOR GENERAL  
VENTILATION APPLICATIONS**

**With  
Synthetic Media  
Class F7**

**Test Report  
Report Number: DEF 061001\_T1  
30/10/06**

**according to EN 779:2002**

**Initiated by:**

**Delta Filtration Ltd.**

Requested by:

Delta Filtration Ltd.  
Kilmallock Industrial Estate  
Bruree Road  
Co Limerick  
Ireland

Order:

Mr. Donal McGoey

Subject:

Performance test of pocket filter device utilizing synthetic media according to EN 779:2002.

Sample:

Pocket filter F7 with eight pockets in metal frame.

Test method:

Sample was received on October 20<sup>th</sup>, 2006.  
Test has been performed on October 26<sup>th</sup>, 2006.

Test has been performed following the procedures as defined in EN 779:2002 "Particulate air filters for general ventilation - Requirements, testing, marking". The efficiencies have been tested with diluted DEHS (10% DEHS in isopropylalcohol)


Refer to page 2 of the attachments for details of instrumentation.

Results:

See attachments for detailed information. The findings are summarized on page 1 of the attachments.

The results apply to the tested specimen only. Filter performance data of related filters of the same design and media will be similar. Filtration performance under certain application conditions cannot necessarily be predicted from these data.

Monday, October 30<sup>th</sup>, 2006



H. Bittermann



Filter & Aerosol Technologie GmbH

**AIR FILTER TEST CERTIFICATE ACCORDING TO: EN 779:2002**

**SUMMARY PAGE**

Testing organisation: **fiatec Filter & Aerosol Technologie GmbH**

Report no.: **DEF 061001\_T1**

**GENERAL**

Test no.: <b>DEF 061001_T1</b>	Date of test: <b>26.10.06</b>	Supervisor: <b>H. Bittermann</b>
Test requested by: <b>Delta Filtration Ltd.</b>	Device received: <b>20.10.2006</b>	
Device delivered by: <b>Delta Filtration Ltd.</b>		

**DETAILS OF DEVICE**

Model: <b>F7 Bagfilter</b>	Manufacturer: <b>Delta Filtration</b>	Construction and design: <b>Pocket filter with eight pockets in metal frame</b>
Type of media: <b>Synthetic Media</b>	Net effective filtering area [m <sup>2</sup> ]: <b>6,2 m<sup>2</sup></b>	Dimensions: <b>length x width x height [mm] 592x592x650</b>


**TEST DATA**

Test air flow rate: <b>3400 [m<sup>3</sup>/h]</b>	Test air temperature: <b>23 ± 1 [°C]</b>	Rel. Humidity: <b>55 ± 3 [%]</b>
Test aerosols	Efficiency: <b>10% DEHS</b>	Test aerosols: <b>ASHRAE 52/76</b>

**RESULTS**

Initial pressure drop: <b>82 [Pa]</b>	Initial arrestance: <b>94,8 [%]</b>	Initial Efficiency: <b>59,09 [%]</b>	Influence of Charges-Media check at 0,4 µm: <b>Discharged eff. [%]</b>
Final pressure drop: <b>450 [Pa]</b>	Average arrestance: <b>97,8 [%]</b>	Average Efficiency: <b>81,51 [%]</b>	Filter Class: <b>F7</b>
			Dust Holding Capacity [g]: <b>450 Pa</b>
			Remarks: <b>172</b>

Note: The performance results apply to the tested item and do not allow to predict performance in actual service under specific conditions



26.10.2006

Date

Signature



Filter & Aerosol Technologie GmbH

Report no.: DEF 061001\_T1

EN 779:2002

AIR FILTER TEST CERTIFICATE ACCORDING TO:

**INSTRUMENTATION**

fiatec Filter & Aerosol Technologie GmbH

Testing organisation:

Test no.:	DEF 061001_T1
Date of test:	26.10.06
Test mode:	EN 779:2002
Sample ID:	N/A

**TEST DUST DISPERSION**

Dust loading:	ASHRAE 52/76	Efficiency measurements:	10 % DEHS
Test dust:	Fiatec	Test dust:	UGF 1000
Generator:	Fiatec	Generator:	5 x 10 <sup>5</sup> Particles/l
Concentration:	70 mg/m <sup>3</sup>	Concentration:	

**PARTICLE COUNTING**

Particle counter (Make/Model):	TSI Inc. APS 3321
Working Principle:	Aerodynamic Laser Counter, Time of Flight Spectrometer
Sampling:	6 samples up- and downstream of device, 60 seconds each
Sample Probes:	Effective Diameter 6 mm
Sample Flow:	5 l/min
Software:	Aerosol Instrument Manager 3.0

**FLOW MEASUREMENTS**

Make/Model:	Quantometer + Wilson Grid
Working Principle:	Turbine Gas Meter + Prandtl Tube

**PRESSURE DROP, HUMIDITY AND TEMPERATURE**

Pressure drop accuracy:	5 Pa
Humidity:	Controlled: Set Point 55 ± 3 %
Temperature:	Controlled: Set Point 23 ± 1°C



Filter & Aerosol Technologie GmbH

Report no.: DEF 061001\_T1

Testing organisation: fiatec Filter & Aerosol Technologie GmbH

**Table 1: Collection Efficiencies at Various Dust Loads**



AIR FILTER TEST CERTIFICATE ACCORDING TO: EN 779:2002

Test no.: DEF 061001_T1	Date of test: 26.10.06	Test mode: EN 779:2002	Sample ID: N/A
-------------------------	------------------------	------------------------	----------------

**Table 1: Efficiencies at Various Dust Loads**

Particle Size (aerodynamic) (µm)	New Device		30 g Dust		150 Pa		220 Pa		320 Pa		450 Pa	
	$\eta_{mean}$ (%)	$\Delta\eta_{max}$ (%)	$\eta_{mean}$ (%)	$\Delta\eta_{max}$ (%)	$\eta_{mean}$ (%)	$\Delta\eta_{max}$ (%)	$\eta_{mean}$ (%)	$\Delta\eta_{max}$ (%)	$\eta_{mean}$ (%)	$\Delta\eta_{max}$ (%)	$\eta_{mean}$ (%)	$\Delta\eta_{max}$ (%)
0,423	59,09	1,26	67,78	1,01	81,38	0,71	90,41	0,70	95,00	0,29	97,75	0,38
0,542	59,29	0,84	68,39	0,76	82,16	0,16	91,62	0,26	95,97	0,24	98,21	0,27
0,583	60,16	0,13	69,42	0,71	83,01	0,19	92,24	0,18	96,59	0,18	98,49	0,18
0,626	61,29	0,65	71,11	0,56	84,36	0,15	93,01	0,30	97,07	0,25	98,77	0,05
0,673	62,44	0,95	72,75	0,66	85,64	0,30	93,90	0,25	97,43	0,47	98,97	0,08
0,723	63,29	0,30	74,04	0,78	86,61	0,21	94,31	0,28	97,70	0,24	99,11	0,18
0,777	64,98	0,57	75,33	1,33	87,61	0,15	95,00	0,16	98,04	0,31	99,33	0,08
0,835	66,07	0,40	76,91	0,64	88,87	0,20	95,82	0,49	98,59	0,21	99,57	0,08
0,898	67,58	0,37	78,68	0,44	90,01	0,71	96,51	0,23	99,01	0,14	99,73	0,08
0,965	68,86	1,07	80,16	0,59	91,12	0,29	97,42	0,31	99,31	0,15	99,82	0,05
1,037	70,70	1,56	82,03	0,46	92,67	0,29	98,02	0,35	99,57	0,07	99,89	0,08
1,114	73,01	0,53	84,18	0,57	94,00	0,55	98,60	0,26	99,74	0,04	99,94	0,04
1,197	75,07	1,88	86,74	0,40	95,24	0,57	99,07	0,13	99,84	0,03	99,94	0,00
1,286	77,74	1,01	88,61	0,12	96,45	0,86	99,32	0,07	99,94	0,02	99,99	0,03
1,382	80,85	0,52	90,71	0,30	97,24	0,86	99,65	0,19	99,93	0,06	99,96	0,06
1,486	83,03	0,25	92,01	0,92	97,82	0,70	99,75	0,12	99,97	0,08	99,98	0,04
1,596	85,85	0,52	93,32	1,07	98,51	0,26	99,78	0,11	99,95	0,08	99,98	0,03
1,715	87,67	1,70	94,55	1,06	98,80	0,34	99,90	0,03	100,00	0,00	99,95	0,09
1,843	90,60	2,38	96,28	0,36	99,24	0,11	99,95	0,00	99,97	0,05	99,97	0,08
1,981	91,88	2,43	96,99	0,38	99,67	0,12	99,96	0,13	99,98	0,06	100,00	0,00
2,129	93,66	1,24	98,38	0,84	99,52	0,16	100,00	0,00	99,92	0,25	99,90	0,23
2,288	95,98	0,53	98,53	0,87	99,85	0,01	100,00	0,00	99,96	0,11	100,00	0,00
2,458	96,85	1,32	99,16	0,98	99,78	0,46	100,00	0,00	100,00	0,00	99,90	0,17
2,642	98,39	2,33	99,38	1,31	99,83	0,51	99,75	0,51	100,00	0,00	100,00	0,00
2,839	99,47	1,02	99,87	0,40	99,89	0,34	100,00	0,00	100,00	0,00	100,00	0,00
3,051	98,99	2,13	99,77	0,70	100,00	0,00	99,66	0,53	100,00	0,00	100,00	0,00

\*  $\eta_{mean}$  is the average efficiency at a certain loading phase calculated from six single concentration measurements up- and downstream of the filter.  
 \*\*  $\Delta\eta_{max}$  represents the absolute range of the values measured for each size channel.



Test no.: DEF 061001_T1	Date of test: 26.10.2006	Test mode: EN 779:2002
Loading Dust: ASHRAE 52/76	Eff. Aerosol: 10% DEHS	Sample ID: N/A
Air Flow [m³/h]: 3400		

Testing organization: fiatec Filter & Aerosol Technologie GmbH  
 Report no: DEF 061001\_T1

**AIR FILTER TEST CERTIFICATE ACCORDING TO: EN 779:2002**

**fiatec** Filter & Aerosol Technologie GmbH

**EFFICIENCIES AND PRESSURE DROP DIAGRAMS**



Filter & Aerosol Technologie GmbH

Report no.: DEF 061001\_T1

AIR FILTER TEST CERTIFICATE ACCORDING TO: EN 779:2002

DUST LOADING AND PRESSURE DROP DATA

Testing organisation:

fiatec Filter & Aerosol Technologie GmbH

Test no.:	DEF 061001_T1	Date of test:	26.10.06	Test mode:	EN 779:2002	Sample ID:	N/A
-----------	---------------	---------------	----------	------------	-------------	------------	-----

Pressure Drop vs Air Flow

Air Flow	[m³/h]	[m/s]	[kg/h]	[m³/min]	[Pa]
0	0	0	0	0	0
1000	1185	1778	1185	17	18
1500	1778	2370	1778	25	28
2000	2370	2963	2370	33	39
2500	2963	3555	2963	42	52
3000	3555	4029	3555	50	67
3400	4029	4740	4029	57	82
4000	4740	5036	4740	67	105
4250	5036		5036	71	118

Pressure Drop, Arrestance and Efficiency vs Dust Feed and Dust Collection at 3400 m³/h

	[g]	[g]	[g]	[g]	[Pa]	[%]	[%]	[g]
Dust Fed (differential)	0,0	0,0	0,0	0,0	82	59,09	59,09	2595,8
Dust Fed (cumulated)	30,6	30,6	29,0	29,0	94,8	67,78	63,43	2624,8
Dust Collected (cumulated)	50,6	81,2	49,5	78,5	97,8	81,38	69,42	2674,3
Dust Collected (differential)	176,1	147,9	27,7	142,2	97,5	95,00	78,73	2740,0
Average Arrestance	99,5	98,6	98,4	97,2	94,8	97,8	97,5	2768,0
Average Arrestance	94,8	94,8	96,7	97,2	82	59,09	59,09	2595,8
AP	94,8	94,8	96,7	97,2	82	59,09	59,09	2595,8
Efficiency at 0.4µm	97,5	97,5	97,2	97,2	94,8	97,8	97,5	2768,0
Average Efficiency 0.4 µm after each loading step	81,90	81,90	81,38	81,38	94,8	67,78	63,43	2624,8
Average Efficiency	81,51	81,51	81,38	81,38	94,8	67,78	63,43	2624,8
Weight of Device at Various Loading Stages	2740,0	2740,0	2712,3	2712,3	94,8	97,8	97,5	2768,0

Average Efficiency [%] at 450 Pa:	81,5
Dust Holding Capacity [g] at 450 Pa:	172,3
Average Arrestance [%] at 450 Pa:	97,8